



Nightspot A LED 8 965 1.4 ...  
 Anbauleuchte 8 965 1.6 ...  
 Luminaire 8 965 6.4 ...  
 8 965 6.6 ...

Schutzart - Protection IP 65  
 Schutzklasse - Safety Class I



MONTAGE  
 ANLEITUNG  
 MOUNTING  
 INSTRUCTIONS



WILLY MEYER & SOHN GMBH & CO.KG  
 LICHTTECHNISCHE SPEZIALFABRIK  
 Stemmessiepener Weg 5 • D-58675 Hemer

Scheinwerfer mit 4 x 1,5 W Hochleistungs-LEDs.


Luminaire with 4 x 1,5 W high performance LEDs.

#### MONTAGEHINWEISE

Anschluß der Leuchte nach VDE 0100.  
 Anbauleuchte für ungeschützte Anlagen.  
 Leuchte ist geeignet für Montage auf normal entflammaren Baustoffen.  
 Vor dem Öffnen der Leuchte oder LED-Wechsel Netzspannung trennen.  
 Gewindestift am Sockel lösen.  
 Leuchtensockel am Montageort anbringen.  
 Leuchte auf Sockel aufsetzen, ausrichten und mit Gewindestift fixieren.

Zum Wechsel des Leuchtmittels Rahmen mit Glas und LEDs vom Gehäuse nehmen. LEDs im Rahmen tauschen. Beim Aufsetzen auf das Gehäuse Rahmen mit Schrauben über Kreuz dicht verschrauben. Beim Zusammenbau auf korrekten Schutzleiteranschluß achten.

Das Glas ist ein Einscheiben-Sicherheits-Hartglas.



Die Leuchte darf nur mit ihren vollständigen Schutzabdeckungen betrieben werden.

Leuchte	Gewicht	Windangriffsfläche
8 965 1.. ...	1,2 kg	0,015 m <sup>2</sup>
8 965 6.. ...	1,5 kg	0,035 m <sup>2</sup>

In Strahlrichtung den Mindestabstand zu angestrahlten Flächen einhalten !




#### MOUNTING INSTRUCTIONS

Connection of the light fitting in compliance with the prevailing regulations in your country.  
 Luminaire for non protected outdoor installation.  
 Luminaire is suitable for mounting on normal inflammable surfaces. Disconnect from power supply before opening the light fitting.  
 Loosen the grub screw in the base.  
 Install the luminaire base in the required position.  
 Place lighthouse on base, aim luminaire and then tighten grub screw.

To change the LED board: Remove the front frame complete with glass and LED board.  
 Change the LED board in the frame.  
 Replace front frame assembly and tighten screws diagonally. During assembly ensure that the earth wire is connected correctly.

The glass is tempered safety glass.



Luminaire may be operated only when all protective covers are in place.

Luminaire	weight	projected area
8 965 1.. ...	1,2 kg	0,015 m <sup>2</sup>
8 965 6.. ...	1,5 kg	0,035 m <sup>2</sup>

Ensure that the minimum spacing between luminaire and illuminated surface is observed.

